



ADDENDUM 2

October 18, 2018

ITB FM 60-18

DEMOLITION, DISPOSAL AND REBUILD OF FISHING PIER AT MARLER PARK

This addendum is to answer the following questions:

1. Can moisture shield composite decking be used on this project?

Yes, however, it must meet the same load limits and span limits as the treated wood 2 by material. If used, it may require additional floor bracing than the original plans listed. We would require documentation as to the specs before final inspection and approval.

2. Do pilings need to be wrapped in polyethylene?

No

3. What is the project's estimated cost?

Under \$250,000

4. Are state, federal and county permits required?

The contractor is required to provide any permit necessary. Liability is for contractor to ascertain the need for all (State, Federal, and County).

5. Is retaining wall to be replaced? Is temporary wall to be removed?

We are not certain the condition of the retaining wall. The need for replacement would require approval from County staff before proceeding.

See attached updated bid sheet to include an allowance not to exceed \$2500.00.

**The temporary wall will be removed by County staff. **

**Additionally, and if fill material is required, it must be approved by County staff as to the type of material to be used. **

6. Does contractor need to post work signs?

Yes

Notes:

Ramp needs to be wheelchair accessible. Handrails and top piece to be removed by County and re-purposed. Contractor to be given room to stage and store materials. However, the site is not secured.

County to identify-erosion piece needs to be built up where dock connects to land.

BID SHEET

Bid #: ITB FM 60-18

BID ITEM: Demolition, Disposal & Rebuild of Fishing Pier at Ross Marler Park

Total Bid Amount to for demo and disposal: \$ _____





Total Bid Amount for re-build of pier: \$ _____

Allowance for Retaining Wall: \$ \$2500.00 _____

Total Bid Amount: \$ _____

Total number of days to complete the project (demo, dispose and rebuild): _____

SIGN IN SHEET
Demolish/Rebuild/Dispose-Ross Marler Park Pier:
ITB FM 60-18
Non-Mandatory Pre-Bid Meeting
October 2, 2018 @ 8:00 AM CST

COMPANY/DEPARTMENT	SIGNATURE	TELEPHONE #	EMAIL ADDRESS (PLEASE PRINT NEATLY)
Morgan Maria L.		850 399 1878	MorganMariae1@ Verizon.com
R. J. GORHAM MARINE		950-690-5297	CHRISTOPHER 123 BOND MARINE.COM
HE HARDERS + SON, INC		850-874-1500	BCRITTENDEN E HEHARDERS.COM
LOFTIS MARINE		850-572-3718	LOFTISMARINE@gmail.com