

ADDENDUM NO. 2
to the
PROJECT DOCUMENTS AND SPECIFICATIONS
for
CEW HIGH MAST LIGHT REPLACEMENT
BOB SIKES AIRPORT
(ITB AP 15-18)

Prepared for:
OKALOOSA COUNTY

Prepared By:



320 Bayshore Drive, Suite A
Niceville, Florida 32578-2425

AVCON Project No. 2017.050.06

Addendum Date: February 22, 2018

Note: The bidder shall acknowledge receipt of this addendum on the Bid Form, Page BF-1 in the space provided.

ADDENDUM NO. 2
CEW HIGH MAST LIGHT REPLACEMENT
BOB SIKES AIRPORT
(ITB AP 15-18)

- Date of Issue:** February 22, 2018
- Bid Submittal Deadline:** February 28, 2018 @ 2:00 p.m. (Central Standard Time) **(No Change)**
302 North Wilson Street, Conference Room #305, Crestview, Florida 32536
- Notice to all Plan Holders:** Please insert this addendum (2 pages including cover, excluding attachments) into your copy of the Project Bid Documents.

The following changes to the Project Documents and Specifications are issued by the Engineer and shall have the same force and effect as though part of the original issue:

A. Additional Information:

1. Responses to Questions Additional photometric information was provided for the Bright Light Systems NOVA HM LED light fixture. Can this light fixture be considered an approved equal light fixture?

Response: The photometric calculations provided for this fixture do not provide the same of greater light levels provided by the specified fixture; therefore, this fixture is not considered an approved equal light fixture.

END OF ADDENDUM NO. 2