

**ADDENDUM NO. 6**  
**to the**  
**PROJECT DOCUMENTS AND SPECIFICATIONS**  
**for**  
**CONSTRUCT OKALOOSA COUNTY WATER AND SEWER**  
**FIELD OFFICES**  
**(ITB WS 02-21)**

**Prepared for:**  
**OKALOOSA COUNTY**

**Prepared By:**



**320 Bayshore Drive, Suite A**  
**Niceville, Florida 32578-2425**

**AVCON Project No. 2018.125.02**

**Addendum Date: December 4, 2020**

Note: The bidder shall acknowledge receipt of this addendum on the Bid Form, Page BF-1 in the space provided.

**ADDENDUM NO. 6**  
**CONSTRUCT OCWS FIELD OFFICES**  
**(ITB WS 02-21)**

- Date of Issue:** December 4, 2020
- Bid Submittal Deadline:** Wednesday, December 9, 2020 @ 3:00 p.m. (local time) *(UNCHANGED)*
- Notice to all Plan Holders:** Please insert this addendum (2 pages including cover, excluding attachments) into your copy of the Project Bid Documents.

The following changes to the Project Documents and Specifications are issued by the Engineer and shall have the same force and effect as though part of the original issue:

**A. Changes to the Bid Documents and Specifications:**

1. Wall Panel Requirements **REVISE** exterior wall panel requirements to specify that the exterior wall panels shall be 36-inch standard PBR metal building wall panels.

**END OF ADDENDUM NO. 6**