



ADDENDUM 2

ITB PW 24-19

Golf Links Stormwater Improvements

Date of Issue: January 29, 2019

Bid Submittal Deadline: The Bid Date and submission time has NOT CHANGED.

This Addendum will address the following questions:

1. Does bid item #12, Borrow Excavation, include all earthwork and establishing grade activities?
 - a. All Earthwork, Excavation, and Grading activities for slope grading (performed in accordance with Specs Section 2200) are included in bid items #12 and #13 for Borrow Excavation and Embankment. Bid items #12 and #13 do not include pipe installation earthwork costs, which are to be included in the cost of pipe.
2. Bid item #29, Asphalt Paving Type SP 9.5, includes the overlay but there is no item to account for open cut area of asphalt. Can a line item be added to include asphalt removal and replacement/patch?
 - a. The Asphalt Paving Type SP 9.5 bid item #29 includes both the parking lot overlay and the pavement patch required for the pipe construction. Flexible pavement removal is included in the Clearing and Grubbing bid item #3.
3. Should the Contractor include striping for the parking lot spaces?
 - a. Please refer to Section VI "Signing and Traffic Notes" of the General Notes (Sheet C-002), numbers 8, 9, and 13. Striping cost to be included in the cost of the pavement overlay, bid item #29.