

## Questions for RFB FM/AP 04-15

1. **What is the frequency of testing for fire pumps?**

The pumps should be tested weekly.

2. **Should the price for the pump runs be specified on Line Item #6?**

Yes, the pricing should be specified on Line Item #6.

3. **How many fire pumps are throughout the county?**

There are 3(maybe 4).

4. **Will all locations require a weekly pump run?**

Here are the following locations that will require a weekly pump run:

- Courthouse Annex Extension – Fort Walton Beach
- The Northwest Florida Regional Airport (VPS), Valparaiso
- Bob Sikes Airport (CEW), Crestview

5. **How many fire extinguishers will need to be inspected throughout the county?**

There are 425 Fire extinguishers throughout Okaloosa County.

6. **What are the types and sizes of the fire extinguishers?**

Here's a list of the type, sizes and the number of extinguishers we currently have:

Type & Size		Number of Extinguishers
<b>ABC</b>	2.5lb	7
	5lb	220
	10lb	104
	20lb	40
<b>BC</b>	2.5lb	4
	5lb	4
	10lb	30
	20lb	14
<b>K</b>	6L	2

7. **Should service and replacement pricing of fire extinguishers be included?**

Yes

8. **Should the bid sheet reflect the sum of all inspections or should a bid sheet be created for each property?**

Yes, it should reflect the sum of all inspections and all properties that are listed in the bid.

9. **Should the bid also include a 6 year maintenance agreement and pricing for Hydro Testing?**

Yes