



ADDENDUM NO. 1

August 11, 2020

TO: ALL BIDDERS

PROJECT: ITB PW 69-20 – Miscellaneous Landscape Improvements

BID TIME AND DATE: 3:15 PM LOCAL TIME, August 19, 2020 (NO CHANGE)

The following items are hereby incorporated into the project manual, procurement documents, contract documents, plans and specifications:

ITEM NO. 1

– QUESTIONS RECEIVED POST ADVERTISEMENT

Question 1 – “Are we responsible for the Arterial and Limited Access Landscape Roadway Sign?”

Answer: No. Arterial and Limited Access Landscape Roadway signs if approved shall be provided and replaced by the local government entity as described in 14-40.003, (7), (c) Highway Landscape Projects.

Question 2 – “Are we responsible for the electrical power to the transformers for the lighting?”

Answer: Yes. Please refer to the Lighting Notes and Lighting Details beginning on LD-24 of ‘Set (b)_Emerald Coast Community Gateways Release For Bid’ drawings.

Question 3 – “Where is the closest power source for the lighting? What type?”

Answer: 110 single-phase. Please refer to ‘Set (b)_Emerald Coast Community Gateways Release For Bid’ drawings for the Approx. Location of Electric POC.

END OF QUESTIONS

RECEIPT OF THIS ADDENDUM SHALL BE ACKNOWLEDGED BY WRITING THIS ADDENDUM NUMBER AND DATE IN THE SPACE PROVIDED ON DOCUMENT 00410-7, ‘*ADDENDUM ACKNOWLEDGEMENT - ATTACHMENT A.*’