

**ADDENDUM RECEIPT**

**Addendum No:** 1

**Date:** Sept 20, 2019

**Project:** Subsurface Utility Contract (2019)

**ITB:** WS 77-19

**Pages to Follow:** 6

**Bidders must acknowledge receipt of all issued addenda  
by signing and dating this receipt and faxing to (850) 689-5970  
or scanning and emailing to [dmason@myokaloosa.com](mailto:dmason@myokaloosa.com)**

\_\_\_\_\_  
COMPANY

\_\_\_\_\_  
AUTHORIZED SIGNATURE

\_\_\_\_\_  
PRINTED NAME

\_\_\_\_\_  
DATE

**It shall be the responsibility of Prime Bidders to insure that Subcontractors and/or Suppliers receive addenda which could impact their respective portions of the project. Additional instructions for addenda acknowledgement can be found in the contract documents.**

## ADDENDUM NO. 1

**TO:** ALL BIDDERS

**PROJECT:** ITB WS 77-19 Subsurface Utility Contract (2019)

**BID TIME AND DATE:** 3:00 PM CST, October 2, 2019

**OWNER:** OKALOOSA COUNTY WATER AND SEWER SYSTEM

September 20, 2019

A Mandatory Pre-Bid Meeting was held on September 10, 2019. Pursuant to issues discussed and questions arising from that meeting as well as questions subsequent to that meeting, the following items are hereby incorporated into the project contract documents and specifications. **Note, any deletions from original documents will be ~~stricken through~~ and any additions or replacements of deletions shall be *italicized* in this addendum:**

### ITEM NO. 1 – Page 00002, Notice to Respondents

Emphasized the following information:

- Bid time and date for receipt of bids is **3:00 PM** local time on **Oct. 2, 2019**
- Bids will be opened at that time.
- **Note - Not a Next Day Delivery Service**
- **Note – Security at Entry Point – allow time for security clearance if hand delivering**

### ITEM NO. 2 - Page 00003, Bid Requirements

Emphasized the following information:

- Note: A list of quantities of items, to be provided in Final Addendum, shall be used to evaluate bidder's proposal based on the unit prices provided in the official Bid Schedule.... No guarantee of quantities of Work required during this Contract or Work allocated to individual Contractor(s) during the life of the Contract is provided.
- TERM OF CONTRACT

The contract will begin when fully executed by all parties and continue for three (3) years with the option of two (2) one (1) year renewals, with appropriate CPI increases, upon mutual agreement by both parties. The County has the right to award the contract to more than one vendor.

### **ITEM NO. 3 - Page 00004, Cooperative Pricing**

#### **Emphasized the following information:**

- Cooperative Pricing – all governmental agencies within Okaloosa County with same terms. Also Article 22 (00100-6) Authority to Piggyback to any governmental agencies (within State of FL)

### **ITEM NO. 4 - SECTION 00100**

#### **Emphasized the following information:**

- Pre-Bid Activity (00100-1) - Questions and answers must be in writing. No questions will be answered that are received after September 20, 2019. Final addendum (including revised bid schedule, see below) will be issued via email no later than September 25, 2019 as early as practicable.
- Preparation of Bid (00100-1) - Original + 2 copies of the bid form. All originals signed in blue ink.
- Article 4 (00100-2 and 3) - Submittal of Bid - Again, **not a next day delivery**
- Article 19 (00100-5) - Conflict of Interest – Certification Form is included with Bid Package
- Article 23 (00100-6) – CONE OF SILENCE - Certification Form is included with Bid Package
- Article 33 (00100-8) BID DOCUMENTS – Must submit all listed documents or may be deemed non-responsive.

### **ITEM NO. 5 - SECTION 00300**

- 00300-Bid Schedule (beginning on 00300-1) Additions will be made to the bid schedule to add the following:
  - a) larger butt fused HDPE Pipe Adapter Fittings that were inadvertently omitted from original bid schedule
  - b) an item for 3” conduit
  - c) separate pricing of larger sized Fusion Machine Mobilization and Carrier Pipe installed inside Jack and Bore Casing as follows. Be aware that the number of mobilizations for large fusing machine mobilizations will be negotiated per Task Order, depending on foreseen circumstances and proposed scope/scheduling.
  - d) ductile iron carrier pipe installed inside jack and bore casing (which is priced separately elsewhere in bid schedule)

*Please be preparing pricing for these additional items which will be included in the final revised bid schedule with updated item numbering:*

Item #		Unit	UNIT PRICE
	<b>Butt Fused HDPE Pipe Adapter - HDPE to MJ Adapter Fitting (Same Size)</b>		
*	30" HDPE MJ Adapters	PAIR	
*	36" HDPE MJ Adapters	PAIR	
	<b>Horizontal Directional Drill Installation of HDPE DR-11 Communication Conduit (Orange)</b>		
*	1 x 3" HDPE w/pull tape (0'-250')	LF	
*	1 x 3" HDPE w/pull tape (> 250')	LF	
	<b>Fusion Machine Mobilization (HDPE and FPVC)</b>		
*	Additional charge for 16"-30" Fusion Machine Mob	EA	
*	Additional charge for 36" Fusion Machine Mob	EA	
	<b>Ductile Iron Carrier Pipe Installed Inside Jack and Bore Casing (Restrained Joint Ductile Iron Pipe with Casing Spacers and Casing End Seals)</b>		
*	4" CL350 DIP	LF	
*	6" CL350 DIP	LF	
*	8" CL350 DIP	LF	
*	10" CL350 DIP	LF	
*	12" CL350 DIP	LF	
*	14" CL250 DIP	LF	
*	16" CL250 DIP	LF	
*	18" CL250 DIP	LF	
*	20" CL250 DIP	LF	
*	24" CL250 DIP	LF	
*	30" CL250 DIP	LF	
*	36" CL250 DIP	LF	
*	42" CL250 DIP	LF	

- A FINAL REVISED Section 00300 Bid Schedule will be included at the end of the Final Addendum. **USE the FINAL REVISED Section 00300 to submit your bid!**
- Proposal Evaluation – Re-iterated proposal evaluation covered on page 00001

**ITEM NO. 6 - SECTION 00451 Qualifications Statement**

- Schedules A and B (pages 00451-8 through 00451-10) may include only current and previous experience during last five years with maintenance and/or service contracts. You are **NOT** required to list all current projects or include all previous projects completed within the last five years, as noted on Schedule B.
- For “Cost of Work” (last column) on both schedules, please indicate total work completed to date for current projects (Schedule A) and the total final

completed contract amount for previous work (Schedule B).

#### **ITEM NO. 7 - SECTION 00520**

**Emphasized the following:**

- 4.01 Time – Three-year contract with option for 2 one-year additional renewals (00520-1), with appropriate CPI increases at each renewal.
- 4.03 Contract Times: Days – Substantial and final completion dates for each Task Order
- 4.04 Liquidated Damages - \$500 per day, based on dates in each task order
- 6.02 – Retainage – will be per Task Order, not for entirety of contract.

#### **ITEM NO. 8- SECTION 00800 Supplementary Conditions**

Note SC-5.04 Insurance Requirements (00800-1 and 2). Particularly note State of FL Workmen's Comp requirements and assure that you will have appropriate FL WC during life of this contract.

#### **ITEM NO. 9 - SECTION 00950 Special Conditions**

- Article 22 (00950-7) Hydrant Meter - no charge for water but Contractor must acquire hydrant meter from OCWS, with refundable deposit.

#### **ITEM NO. 10 -SECTION 01150 Measurement and Payment**

All bid items should be covered specifically in this section. Changes to this Section are as follows:

- 2.10 Section 33 05 23.16, Jacking and Boring of Utility Pipe
  - A. Payment for furnishing all labor, materials, equipment and services required for the complete installation of casing pipe by boring or jacking methods, including all classes of excavation, crushed stone, concrete, ~~wøøden blocks~~, anchors, straps, etc., all in accordance with these Specifications and details shown on the Drawings, shall be made at the applicable unit price bid in the Bid Form and the actual number of linear feet of casing pipe installed....
  - B. Carrier pipe shall be furnished, installed and paid for under applicable provisions of the piping sections of these Specifications at the unit price bid under the respective section in the Bid Form *and shall include restrained joint ductile iron carrier pipe, stainless steel casing spacers and casing seals at each end of the casing.***

**ITEM NO. 11 – Section 33 05 23.12**

- The table in Paragraph 1.1.C.2 shall be replaced in its entirety with the following:

Nominal Size (in)	DR	Material	Pressure Class (psi)	Avg. I.D. (in)
4	DR 18	Fusible C-900	235	4.23
6	DR 18	Fusible C-900	235	6.09
8	DR 18	Fusible C-900	235	7.98
10	DR 18	Fusible C-900	235	9.79
12	DR 18	Fusible C-900	235	11.65
14	DR 18	Fusible C-905	235	11.65
16	DR 18	Fusible C-905	235	15.35
18	DR 18	Fusible C-905	235	17.2
20	DR 18	Fusible C-905	235	19.06
24	DR 18	Fusible C-905	235	22.76
30	DR 21	Fusible C-905	200	28.77
36	DR 21	Fusible C-905	200	34.43

**ITEM NO. 12– Section 33 05 23.14 Utility Directional Drilling Pressure Testing**

**Emphasized the following:**

2.4 TEST EQUIPMENT

Provide calibrated pressure gauges, pressure chart recorder, pipes, pumps, meters, and other equipment necessary to perform the hydrostatic pressure test. All equipment and appurtenances necessary for pressure testing, including but not limited to a test cap with 2” nipple and stainless-steel ball valves, shall be provided by the Contractor.

**ITEM NO. 13– Section 33 05 23.16 Utility Pipe Jacking and Boring**

- Paragraph 3.1-L shall read as follows:

The carrier pipe shall be held concentric within the casing pipe by the use of ~~hardwood blocks~~ **stainless steel casing spacers (CCS Series by Cascade Waterworks Mfg. or approved equal)**. The spacing of such blocks or **casing** spacers longitudinally in the casing pipe shall ~~not be~~ **greater than 10 feet be in accordance with the manufacturer’s recommendation and in no case greater than 10 feet and within 2 feet of each end.**

RECEIPT OF THIS ADDENDUM SHALL BE ACKNOWLEDGED BY WRITING THIS  
ADDENDUM NO. AND DATE IN THE SPACE PROVIDED ON PAGE 00300-10 OF  
THE REVISED FINAL BID PROPOSAL.

*Beth Brant, PE*  
Beth Brant, P.E. - POLY, Inc.