

## **EYEWASH STATION INSPECTION CHECKLIST**

INSPECTION FREQUENCY: Eyewash stations shall be inspected quarterly on a fiscal year schedule: 1 <sup>st</sup> Qtr: Oct - Dec / 2 <sup>nd</sup> Qtr: Jan - Mar / 3 <sup>rd</sup> Qtr: Apr - Jun / 4 <sup>th</sup> Qtr: Jul - Sep				
Loc	ation:	Date:	Time:	
TRAINING				
Have all employees be properly trained on the location(s) of all eyewash stations and their proper use?				
	Yes No - Explain:			
PLUMBED EYEWASH STATIONS				
Are all eyewash stations located within 10 feet of unimpeded travel distance from the hazardous material operation?				
	Yes No - Explain:			
Is the path to all eyewash stations clear and free of obstructions and hazards?				
	Yes No - Explain:			
Are all eyewash stations at the same floor level as the hazard?				
	Yes No - Explain:			
Is the area around all eyewash stations have proper lighting?				
	Yes No - Explain:			
Does each eyewash station have its own highly visible sign?				
	Yes No - Explain:			
Are all eye wash stations signs legible and in good condition?				
	Yes No - Explain:			
Are all eyewash stations activated weekly to verify water flow/clarity, pressure, and proper operation?				
	Yes No - Explain:			

Is the water temperature "tepid" (between 60 - 100° F)?			
□ Yes □ No - Explain:			
Are all eyewash station dust caps and/or covers in-place and serviceable?			
□ Yes □ No - Explain:			
Are all eyewash station drains clear and clean of debris or dirt?			
□ Yes □ No - Explain:			
Are any eyewash stations damaged, unserviceable, and in need of repairs?			
<ul> <li>□ Yes</li> <li>□ No - Explain:</li></ul>			
PORTABLE EYEWASH STATIONS			
Is the eyewash station fluid at the proper level/fill line?			
□ Yes □ No - Explain:			
Has the eyewash station been completely drained, rinsed, and fluid replaced with new solution on a regular basis per the manufacturers instructions/requirements?			
□ Yes □ No - Explain:			
HAND-HELD EYEWASH BOTTLES			
Has all of the eyewash bottles been inspected for shelf-life expiration?			
□ Yes □ No - Explain:			
Are all of the eyewash bottles serviceable and free from damage or leaks?			
□ Yes □ No - Explain:			
INSPECTOR SIGNATURE			
Form completed by:			
Name (Print):          Date:			